

September 24, 2025

Mr. Timothy Rowan
Erie 2-Chautauqua-Cattaraugus BOCES
8685 Erie Road
Angola, New York 14006

Re: Lead Testing in School Drinking Water

Dear Mr. Rowan:

Included with this letter is Stohl Environmental LLC's report for the Lead in Drinking Water Sampling performed for Erie 2-Chautauqua-Cattaraugus BOCES including:

- **LoGuidice Educational Center – 9520 Fredonia-Stockton Rd, Fredonia, NY**

This report is prepared to assist school districts in complying with the requirements of 10 NYCRR Subpart 67-4: *Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 5 parts per billion (ppb)".

Sampling was performed on June 26, 2025 and August 14, 2025. As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 49 sources of potable water at the LoGuidice Educational Center have been identified as having lead concentrations in water above the NYS Action Level of 5 parts per billion. To comply with NYS regulations, response actions by the district are required. Response actions are outlined in Section 1.3 (*Response Actions Required Under NYS Regulations*).

Thank you for the opportunity to be of service to Erie 2-Chautauqua-Cattaraugus BOCES.

Sincerely,
Stohl Environmental, LLC.



Michael Scinta
EPA Lead Risk Assessor

Lead Testing in School Drinking Water

Prepared for:

Erie 2-Chautauqua-Cattaraugus BOCES

Prepared by:



**3860 California Road
Orchard Park, New York 14127**

Conditions as of June 26, 2025 and August 14, 2025

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports and Chain of Custody Documents
- 1.5. Laboratory Certifications

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Erie 2-Chautauqua-Cattaraugus BOCES to perform sampling and analysis of potable water for lead concentrations. Sampling was performed in the following building:

- **LoGuidice Educational Center – 9520 Fredonia-Stockton Rd, Fredonia, NY**

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within the LoGuidice Education Center. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, **Subpart 67-4: Lead Testing in School Drinking Water**, and the EPA guidance document, **3Ts for Reducing Lead in Drinking Water in Schools**, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Summary of Samples Collected at the LoGuidice Educational Center:

Building Name	Date of Sampling	Total Samples	At or Below Action Level*	Above Action Level*
LoGuidice Educational Center	June 26, 2025 and August 14, 2025	114	65	49

*NYS Action Level is 5 parts per billion

Listing of Outlets Requiring Remediation

The following outlets were analyzed above the NYS Action Level:

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
199.4A-01	107 B Kitchenette Sink	Sink	18.2
199.4A-02	107 C Lav Sink	Sink	20.3
199.4A-05	109 Sink By Washer/Dryer Left	Sink	5.6
199.4A-13	606 B Left Sink	Sink	17.7
199.4A-14	606 B Right Sink	Sink	14.9
199.4A-18	102 Sink	Sink	10.7
199.4A-19	312 Sink	Sink	7.0
199.4A-20	315 Sink	Sink	13.6
199.4A-21	401 Art Room	Sink	7.0
199.4A-23	306 Kettle Fill	Kettle Fill Spout	31.2
199.4A-27	205 D (Really B)	Sink	8.1
199.4B-05	Boys Restroom Sink 112	Sink	7.1
199.4B-08	Uni Restroom By 102	Sink	11.0
199.4B-10	109 Sink	Sink	18.2
199.4B-15	500 I Restroom Sink	Sink	17.5
199.4C-02	Girls Restroom Sink	Sink	50.2
199.4C-03	Boys Restroom Sink	Sink	5.3
199.4Q-03	201 Low Sink	Sink	25.3
199.4Q-06	203 Low Sink	Sink	28.2
199.4Q-09	205 Low Sink	Sink	8.8
199.4Q-10	207 Sink	Sink	5.1

Sample #	Location	Fixture/Outlet type	Laboratory Analysis (in ppb)
199.4Q-11	301 Sink	Sink	13.9
199.4Q-12	303 Sink	Sink	13.0
199.4Q-13	305 Sink	Sink	20.1
199.4Q-14	307 Sink	Sink	17.7
199.4Q-15	309 Sink	Sink	16.2
199.4Q-17	310B Lav Sink	Sink	19.1
199.4Q-18	607 Sink	Sink	29.3
199.4Q-22	614 Low Sink	Sink	14.0
199.4Q-25	610 Drink Fountain	Drinking Fountain	17.8
199.4Q-26	610 Low Sink	Sink	6.9
199.4Q-29	608 Low Sink	Sink	10.8
199.4Q-30	601 A Left Sink	Sink	34.5
199.4Q-32	601 A Right Sink	Sink	10.5
199.4Q-33	605 High Sink	Sink	19.5
199.4Q-34	103 Lav Sink Left	Sink	12.8
199.4Q-35	103 Lav Sink Right	Sink	17.5
199.4Q-36	204 Girls Locker Room DF	Drinking Fountain	29.1
199.4Q-37	Boys Locker Room DF	Drinking Fountain	49.3
199.4Q-38	206 Lav Sink	Sink	872.0
199.4T-01	402 Boys Restroom	Sink	9.8
199.4T-03	404 Girls Restroom	Sink	27.8
199.4T-08	304 Student Lav	Sink	17.6
199.4T-11	302 Staff Lav	Sink	22.2
199.4T-12	203 Women's Lav	Sink	99.4
199.4T-13	200 DF	Drinking Fountain	45.1
199.4T-14	201 Men's Lav	Sink	46.3
199.4T-15	200 Utility Sink	Sink	20.1
199.4T-16	100 Men's Restroom	Sink	34.0

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration more than the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports and Chain of Custody Documents



July 24, 2025

Service Request No:R2508359

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: E2CC BOCES LoGuidice

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory July 02, 2025
For your reference, these analyses have been assigned our service request number **R2508359**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: E2CC BOCES LoGuidice
Sample Matrix: Drinking Water

Service Request: R2508359
Date Received: 07/02/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty six drinking water samples were received for analysis at ALS Environmental on 07/02/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 07/24/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 199.4-01		Lab ID: R2508359-001					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	18.2			1.0	ug/L	200.8	
CLIENT ID: 199.4-02		Lab ID: R2508359-002					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	20.3			1.0	ug/L	200.8	
CLIENT ID: 199.4-03		Lab ID: R2508359-003					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.3			1.0	ug/L	200.8	
CLIENT ID: 199.4-05		Lab ID: R2508359-006					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.6			1.0	ug/L	200.8	
CLIENT ID: 199.4-06		Lab ID: R2508359-007					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.1			1.0	ug/L	200.8	
CLIENT ID: 199.4-08		Lab ID: R2508359-010					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.0			1.0	ug/L	200.8	
CLIENT ID: 199.4-09		Lab ID: R2508359-011					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.6			1.0	ug/L	200.8	
CLIENT ID: 199.4-10		Lab ID: R2508359-012					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.9			1.0	ug/L	200.8	
CLIENT ID: 199.4-11		Lab ID: R2508359-013					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.7			1.0	ug/L	200.8	
CLIENT ID: 199.4-12		Lab ID: R2508359-014					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.2			1.0	ug/L	200.8	
CLIENT ID: 199.4-13		Lab ID: R2508359-015					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	17.7			1.0	ug/L	200.8	
CLIENT ID: 199.4-14		Lab ID: R2508359-016					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	14.9			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 199.4-15		Lab ID: R2508359-017					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.2			1.0	ug/L	200.8	
CLIENT ID: 199.4-18		Lab ID: R2508359-021					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	10.7			1.0	ug/L	200.8	
CLIENT ID: 199.4-19		Lab ID: R2508359-022					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	7.0			1.0	ug/L	200.8	
CLIENT ID: 199.4-20		Lab ID: R2508359-023					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	13.6			1.0	ug/L	200.8	
CLIENT ID: 199.4-21		Lab ID: R2508359-024					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	7.0			1.0	ug/L	200.8	
CLIENT ID: 199.4-23		Lab ID: R2508359-027					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	31.2			1.0	ug/L	200.8	
CLIENT ID: 199.4-24		Lab ID: R2508359-028					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.5			1.0	ug/L	200.8	
CLIENT ID: 199.4-25		Lab ID: R2508359-029					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.4			1.0	ug/L	200.8	
CLIENT ID: 199.4-27		Lab ID: R2508359-031					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	8.1			1.0	ug/L	200.8	
CLIENT ID: 199.4B-02		Lab ID: R2508359-034					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.6			1.0	ug/L	200.8	
CLIENT ID: 199.4B-04		Lab ID: R2508359-036					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.3			1.0	ug/L	200.8	



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4

Service Request:R2508359

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2508359-001	199.4-01	6/26/2025	
R2508359-002	199.4-02	6/26/2025	
R2508359-003	199.4-03	6/26/2025	
R2508359-004	199.4-04A	6/26/2025	
R2508359-005	199.4-04B	6/26/2025	
R2508359-006	199.4-05	6/26/2025	
R2508359-007	199.4-06	6/26/2025	
R2508359-008	199.4-07A	6/26/2025	
R2508359-009	199.4-07B	6/26/2025	
R2508359-010	199.4-08	6/26/2025	
R2508359-011	199.4-09	6/26/2025	
R2508359-012	199.4-10	6/26/2025	
R2508359-013	199.4-11	6/26/2025	
R2508359-014	199.4-12	6/26/2025	
R2508359-015	199.4-13	6/26/2025	
R2508359-016	199.4-14	6/26/2025	
R2508359-017	199.4-15	6/26/2025	
R2508359-018	199.4-16	6/26/2025	
R2508359-019	199.4-17A	6/26/2025	
R2508359-020	199.4-17B	6/26/2025	
R2508359-021	199.4-18	6/26/2025	
R2508359-022	199.4-19	6/26/2025	
R2508359-023	199.4-20	6/26/2025	
R2508359-024	199.4-21	6/26/2025	
R2508359-025	199.4-22A	6/26/2025	
R2508359-026	199.4-22B	6/26/2025	
R2508359-027	199.4-23	6/26/2025	
R2508359-028	199.4-24	6/26/2025	
R2508359-029	199.4-25	6/26/2025	
R2508359-030	199.4-26	6/26/2025	
R2508359-031	199.4-27	6/26/2025	
R2508359-032	199.4B-01A	6/26/2025	
R2508359-033	199.4B-01B	6/26/2025	
R2508359-034	199.4B-02	6/26/2025	
R2508359-035	199.4B-03	6/26/2025	
R2508359-036	199.4B-04	6/26/2025	

Stohl ENVIRONMENTAL

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) ALS
 STOHL Job # 2023L-199.4


Client: E2CC BOCES Contact: Scott Rutkowski
 Building: LoGuidice Location: 9520 Fredonia-Stockton Road Fredonia, NY 14063

LEAD
 Water by 200.8 X Turnaround 10 Days

Sample #	Location	Outlet Type	Time
199.4A-01	107 B kitchenette sink	sink	22:00
199.4A-02	107 c lav sink	sink	22:02
199.4A-03	109 lav sink	sink	22:04
199.4A-04A	109 dfb	df	22:06
199.4A-04B	109 dfb	dfb	22:08
199.4A-05	109 sink by washer/dryer LEFT	sink	22:10
199.4A-06	109 sink by washer/dryer RIGHT	sink	22:12
199.4A-07A	dfb across front doors	df	22:14
199.4A-07B	dfb across front doors	dfb	22:16
199.4A-08	105 sink	sink	22:18
199.4A-09	106 serving line hand wash	sink	22:20
199.4A-10	106 dishwasher sprayer	sprayer	22:22
199.4A-11	106 handwash next to dish wash sprayer	sink	22:24
199.4A-12	106 3 bay sink	sink	22:26
199.4A-13	606 B left sink	sink	22:28
199.4A-14	606 B right sink	sink	22:30
199.4A-15	608 df	df	22:32
199.4A-16	600 df	df	22:34

Notes:
 Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to: Rfrancoine@stohlenvironmental.com

Sampled By: Isaia Sciabarassi Print Name Isaia Sciabarassi Stohl Env: Isaia Sciabarassi Date: 6/26/2025
 Relinquished By: Rebecca Franjoine Print Name Rebecca Franjoine Stohl Env: Rebecca Franjoine Date: 7/2/2025
 Received (Name / Lab): ALS Date: 7/2/25 Time: 1620
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____





Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-199.4

Client: E2CC BOCES

Contact: Scott Rutkowski

Building: LoGuidice

Location: 9520 Fredonia-Stockton Road Fredonia, NY 14063

LEAD
 Water by 200.8 X

Turnaround
10 Days

Sample #	Location	Outlet Type	Time
199.4A-17A	600 dfb	df	22:36
199.4A-17B	600 dfb	dfb	22:38
199.4A-18	102 sink	sink	22:40
199.4A-19	312 sink	sink	22:42
199.4A-20	315 sink	sink	22:44
199.4A-21	401 art room	sink	22:46
199.4A-22A	dfb in 300s	df	22:48
199.4A-22B	dfb in 300s	dfb	22:50
199.4A-23	306 kettle fill	kettle fill spout	22:52
199.4A-24	306 prep sink	sink	22:54
199.4A-25	302 sink by stoves	sink	22:56
199.4A-26	302 sink by windows	sink	22:58
199.4A-27	205 D (really B)	sink	23:00
199.4B-01A	112 dfb	df	23:02
199.4B-01B	112 dfb	dfb	23:04
199.4B-02	112 sink LEFT	sink	23:06
199.4B-03	112 sink RIGHT	sink	23:08
199.4B-04	girls br sink 112	sink	23:10

Notes:
 Please e-mail lab results to labs@stohlenvironmental.com Rfranjoine@stohlenvironmental.com

Sampled By: Isaia Sciabarassi Print Name Stohl Env: Isaia Sciabarassi Date: 6/26/2025
 Relinquished By: Rebecca Franjoine Print Name Stohl Env: Rebecca Franjoine Date: 7/2/2025
 Received (Name / Lab): [Signature] ALS Date: 7/2/25 Time: 1620
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



R2508359

5

Cooler Receipt and Preservation Check Form

Stohl Environmental
E2CC BOCES LoGuldice



Project/Client Stohl

Folder Number _____

Cooler received on 7/2/25 by MLW

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y	N	5a	Did VOA vials have sig* bubbles?	Y	N	NA
2	Custody papers properly completed (ink, signed)?	Y	N	5b	Sig* bubbles: Alk?	Y	N	NA
3	Did all bottles arrive in good condition (unbroken)?	Y	N		Sulfide?	Y	N	NA
4	Circle: Wet Ice Dry Ice Gel packs present?	Y	N	6	Where did the bottles originate?	<u>ALS/ROC CLIENT</u>		
				7	Soil VOA received as:	Bulk	Encore	5035set
								NA

8. Temperature Readings Date: 7/7/25 Time: 1049 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>20.1</u>							
Within 0-6°C?	Y	N	Y	N	Y	N	Y	N
If <0°C, were samples frozen?	Y	N	Y	N	Y	N	Y	N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: 5035 by MLW on 7/7 at 1049
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 7/9 Time: 0825 by: MLW

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO
- 13. Were dissolved metals filtered in the field? YES NO NA
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized _____ Tedlar® Bags Inflated NA

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
>12		NaOH								
≤2	<u>229529</u>	HNO ₃			<u>No lot info</u>		<u>AN</u>	<u>2ml</u>	<u>2/20/25</u>	<u>≤2</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____

Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: MLW

*significant air bubbles: VOA > 5-6 mm ; WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the "Notes" column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an "immediate" hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4

Service Request: R2508359

Sample Name: 199.4-01
Lab Code: R2508359-001
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-02
Lab Code: R2508359-002
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-03
Lab Code: R2508359-003
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-04A
Lab Code: R2508359-004
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-04B
Lab Code: R2508359-005
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4

Service Request: R2508359

Sample Name: 199.4-05
Lab Code: R2508359-006
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By
ECASTROVINCI

Analyzed By
NMANSEN

Sample Name: 199.4-06
Lab Code: R2508359-007
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-07A
Lab Code: R2508359-008
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-07B
Lab Code: R2508359-009
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-08
Lab Code: R2508359-010
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4

Service Request: R2508359

Sample Name: 199.4-09
Lab Code: R2508359-011
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-10
Lab Code: R2508359-012
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-11
Lab Code: R2508359-013
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-12
Lab Code: R2508359-014
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-13
Lab Code: R2508359-015
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4

Service Request: R2508359

Sample Name: 199.4-14
Lab Code: R2508359-016
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-15
Lab Code: R2508359-017
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-16
Lab Code: R2508359-018
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-17A
Lab Code: R2508359-019
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-17B
Lab Code: R2508359-020
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4

Service Request: R2508359

Sample Name: 199.4-18
Lab Code: R2508359-021
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-19
Lab Code: R2508359-022
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-20
Lab Code: R2508359-023
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-21
Lab Code: R2508359-024
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-22A
Lab Code: R2508359-025
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4

Service Request: R2508359

Sample Name: 199.4-22B
Lab Code: R2508359-026
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-23
Lab Code: R2508359-027
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-24
Lab Code: R2508359-028
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-25
Lab Code: R2508359-029
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4-26
Lab Code: R2508359-030
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4

Service Request: R2508359

Sample Name: 199.4-27
Lab Code: R2508359-031
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4B-01A
Lab Code: R2508359-032
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4B-01B
Lab Code: R2508359-033
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4B-02
Lab Code: R2508359-034
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4B-03
Lab Code: R2508359-035
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4

Service Request: R2508359

Sample Name: 199.4B-04
Lab Code: R2508359-036
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7	200.2
200.8	200.2
6010C or 6010D	3005A/3010A
6020A or 6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010C or 6010D	3050B
6020A or 6020B	3050B
6010C or 6010D TCLP (1311) extract	3005A/3010A
6010C or 6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-01
Lab Code: R2508359-001

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	18.2	ug/L	1.0	1	07/18/25 19:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-02
Lab Code: R2508359-002

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	20.3	ug/L	1.0	1	07/18/25 19:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-03
Lab Code: R2508359-003

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.3	ug/L	1.0	1	07/18/25 19:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-04A
Lab Code: R2508359-004

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/18/25 19:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-04B
Lab Code: R2508359-005

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/18/25 19:49	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-05
Lab Code: R2508359-006

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	5.6	ug/L	1.0	1	07/22/25 10:11	07/21/25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-06
Lab Code: R2508359-007

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	07/18/25 19:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-07A
Lab Code: R2508359-008

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/18/25 19:56	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-07B
Lab Code: R2508359-009

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/18/25 19:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-08
Lab Code: R2508359-010

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.0	ug/L	1.0	1	07/18/25 20:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-09
Lab Code: R2508359-011

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.6	ug/L	1.0	1	07/18/25 20:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-10
Lab Code: R2508359-012

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.9	ug/L	1.0	1	07/18/25 20:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-11
Lab Code: R2508359-013

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	07/18/25 20:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-12
Lab Code: R2508359-014

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	07/18/25 20:16	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-13
Lab Code: R2508359-015

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	17.7	ug/L	1.0	1	07/18/25 20:17	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-14
Lab Code: R2508359-016

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	14.9	ug/L	1.0	1	07/18/25 20:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-15
Lab Code: R2508359-017

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	07/18/25 20:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-16
Lab Code: R2508359-018

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/18/25 20:21	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-17A
Lab Code: R2508359-019

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/18/25 20:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-17B
Lab Code: R2508359-020

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/18/25 20:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-18
Lab Code: R2508359-021

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	10.7	ug/L	1.0	1	07/18/25 20:28	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-19
Lab Code: R2508359-022

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.0	ug/L	1.0	1	07/18/25 20:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-20
Lab Code: R2508359-023

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	13.6	ug/L	1.0	1	07/18/25 20:31	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-21
Lab Code: R2508359-024

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.0	ug/L	1.0	1	07/18/25 20:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-22A
Lab Code: R2508359-025

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/18/25 20:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-22B
Lab Code: R2508359-026

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/18/25 20:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-23
Lab Code: R2508359-027

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	31.2	ug/L	1.0	1	07/21/25 10:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-24
Lab Code: R2508359-028

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.5	ug/L	1.0	1	07/21/25 10:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-25
Lab Code: R2508359-029

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.4	ug/L	1.0	1	07/21/25 10:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-26
Lab Code: R2508359-030

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/21/25 10:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4-27
Lab Code: R2508359-031

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.1	ug/L	1.0	1	07/21/25 10:39	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4B-01A
Lab Code: R2508359-032

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/21/25 10:40	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4B-01B
Lab Code: R2508359-033

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/21/25 10:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4B-02
Lab Code: R2508359-034

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	07/21/25 10:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4B-03
Lab Code: R2508359-035

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/21/25 10:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4B-04
Lab Code: R2508359-036

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.3	ug/L	1.0	1	07/21/25 10:48	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2508359-MB1

Service Request: R2508359
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/22/25 09:46	07/21/25	
Lead, Total	200.8	ND U	ug/L	1.0	1	07/18/25 20:02	NA	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2508359-MB2

Service Request: R2508359
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/18/25 19:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2508359-MB3

Service Request: R2508359
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/21/25 10:11	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25
Date Analyzed: 07/18/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 199.4-07B
Lab Code: R2508359-009
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2508359-009MS		Duplicate Matrix Spike R2508359-009DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	19.2	20.0	96	18.5	20.0	93	70-130	4	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25
Date Analyzed: 07/18/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 199.4-08
Lab Code: R2508359-010
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2508359-010MS		Duplicate Matrix Spike R2508359-010DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	5.0	23.7	20.0	94	25.0	20.0	100	70-130	6	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water

Service Request: R2508359
Date Collected: 06/26/25
Date Received: 07/02/25
Date Analyzed: 07/21/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 199.4B-04
Lab Code: R2508359-036
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2508359-036MS		Duplicate Matrix Spike R2508359-036DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	3.3	23.5	20.0	101	23.8	20.0	103	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water

Service Request: R2508359
Date Analyzed: 07/18/25 - 07/22/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2508359-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.7	20.0	104	85-115
Lead, Total	200.8	20.6	20.0	103	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water

Service Request: R2508359
Date Analyzed: 07/18/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2508359-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.1	20.0	111	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water

Service Request: R2508359
Date Analyzed: 07/21/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2508359-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.4	20.0	97	85-115



July 24, 2025

Service Request No:R2508360

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: E2CC BOCES LoGuidice

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory July 02, 2025
For your reference, these analyses have been assigned our service request number **R2508360**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: E2CC BOCES LoGuidice
Sample Matrix: Drinking Water

Service Request: R2508360
Date Received: 07/02/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Thirty eight drinking water samples were received for analysis at ALS Environmental on 07/02/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 07/24/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 199.4B-05		Lab ID: R2508360-001					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	7.1			1.0	ug/L	200.8	
CLIENT ID: 199.4B-06		Lab ID: R2508360-002					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.5			1.0	ug/L	200.8	
CLIENT ID: 199.4B-07		Lab ID: R2508360-003					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.0			1.0	ug/L	200.8	
CLIENT ID: 199.4B-08		Lab ID: R2508360-004					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	11.0			1.0	ug/L	200.8	
CLIENT ID: 199.4B-10		Lab ID: R2508360-007					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	18.2			1.0	ug/L	200.8	
CLIENT ID: 199.4B-11		Lab ID: R2508360-008					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.5			1.0	ug/L	200.8	
CLIENT ID: 199.4B-14		Lab ID: R2508360-012					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.6			1.0	ug/L	200.8	
CLIENT ID: 199.4B-15		Lab ID: R2508360-013					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	17.5			1.0	ug/L	200.8	
CLIENT ID: 199.4C-02		Lab ID: R2508360-015					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	50.2			1.0	ug/L	200.8	
CLIENT ID: 199.4C-03		Lab ID: R2508360-016					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.3			1.0	ug/L	200.8	
CLIENT ID: 199.4D-02		Lab ID: R2508360-018					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.8			1.0	ug/L	200.8	
CLIENT ID: 199.4D-03		Lab ID: R2508360-019					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.2			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 199.4D-04		Lab ID: R2508360-020					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.6			1.0	ug/L	200.8	
CLIENT ID: 199.4T-01		Lab ID: R2508360-021					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	9.8			1.0	ug/L	200.8	
CLIENT ID: 199.4T-03		Lab ID: R2508360-024					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	27.8			1.0	ug/L	200.8	
CLIENT ID: 199.4T-04		Lab ID: R2508360-025					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.6			1.0	ug/L	200.8	
CLIENT ID: 199.4T-05		Lab ID: R2508360-026					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.6			1.0	ug/L	200.8	
CLIENT ID: 199.4T-06		Lab ID: R2508360-027					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.3			1.0	ug/L	200.8	
CLIENT ID: 199.4T-07		Lab ID: R2508360-028					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	4.2			1.0	ug/L	200.8	
CLIENT ID: 199.4T-08		Lab ID: R2508360-029					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	17.6			1.0	ug/L	200.8	
CLIENT ID: 199.4T-09		Lab ID: R2508360-030					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.6			1.0	ug/L	200.8	
CLIENT ID: 199.4T-10		Lab ID: R2508360-031					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.6			1.0	ug/L	200.8	
CLIENT ID: 199.4T-11		Lab ID: R2508360-032					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	22.2			1.0	ug/L	200.8	
CLIENT ID: 199.4T-12		Lab ID: R2508360-033					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	99.4			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 199.4T-13 **Lab ID: R2508360-034**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	45.1			1.0	ug/L	200.8

CLIENT ID: 199.4T-14 **Lab ID: R2508360-035**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	46.3			1.0	ug/L	200.8

CLIENT ID: 199.4T-15 **Lab ID: R2508360-036**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	20.1			1.0	ug/L	200.8

CLIENT ID: 199.4T-16 **Lab ID: R2508360-037**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	34.0			1.0	ug/L	200.8

CLIENT ID: 199.4T-17 **Lab ID: R2508360-038**

Analyte	Results	Flag	MDL	MRL	Units	Method
Lead, Total	3.2			1.0	ug/L	200.8



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4

Service Request:R2508360

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2508360-001	199.4B-05	6/26/2025	
R2508360-002	199.4B-06	6/26/2025	
R2508360-003	199.4B-07	6/26/2025	
R2508360-004	199.4B-08	6/26/2025	
R2508360-005	199.4B-09A	6/26/2025	
R2508360-006	199.4B-09B	6/26/2025	
R2508360-007	199.4B-10	6/26/2025	
R2508360-008	199.4B-11	6/26/2025	
R2508360-009	199.4B-12	6/26/2025	
R2508360-010	199.4B-13A	6/26/2025	
R2508360-011	199.4B-13B	6/26/2025	
R2508360-012	199.4B-14	6/26/2025	
R2508360-013	199.4B-15	6/26/2025	
R2508360-014	199.4C-01	6/26/2025	
R2508360-015	199.4C-02	6/26/2025	
R2508360-016	199.4C-03	6/26/2025	
R2508360-017	199.4D-01	6/26/2025	
R2508360-018	199.4D-02	6/26/2025	
R2508360-019	199.4D-03	6/26/2025	
R2508360-020	199.4D-04	6/26/2025	
R2508360-021	199.4T-01	6/26/2025	
R2508360-022	199.4T-02A	6/26/2025	
R2508360-023	199.4T-02B	6/26/2025	
R2508360-024	199.4T-03	6/26/2025	
R2508360-025	199.4T-04	6/26/2025	
R2508360-026	199.4T-05	6/26/2025	
R2508360-027	199.4T-06	6/26/2025	
R2508360-028	199.4T-07	6/26/2025	
R2508360-029	199.4T-08	6/26/2025	
R2508360-030	199.4T-09	6/26/2025	
R2508360-031	199.4T-10	6/26/2025	
R2508360-032	199.4T-11	6/26/2025	
R2508360-033	199.4T-12	6/26/2025	
R2508360-034	199.4T-13	6/26/2025	
R2508360-035	199.4T-14	6/26/2025	
R2508360-036	199.4T-15	6/26/2025	
R2508360-037	199.4T-16	6/26/2025	
R2508360-038	199.4T-17	6/26/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-199.4

Client: E2CC BOCES

Contact: Scott Rutkowski

Building: LoGuidice

Location: 9520 Fredonia-Stockton Road Fredonia, NY 14063

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
199.4B-05	boys br sink 112	sink	23:12
199.4B-06	110 staff br sink	s	23:14
199.4B-07	108 mens br sink	s	23:16
199.4B-08	uni br by 102	s	23:18
199.4B-09A	dfb by 102	df	23:20
199.4B-09B	dfb by 102	dfb	23:22
199.4B-10	109 sink	s	23:24
199.4B-11	108 left sink	s	23:26
199.4B-12	108 right sink	s	23:28
199.4B-13A	room 300 dfb	df	23:30
199.4B-13B	room 300 dfb	dfb	23:32
199.4B-14	206 sink	s	23:34
199.4B-15	500 i br sink	s	23:36
199.4C-01	teacher br sink	s	23:38
199.4C-02	girls br sink	s	23:40
199.4C-03	boys br sink	s	23:42
199.4D-01	bathroom left of utility sink	s	23:44
199.4D-02	utility sink	s	23:46

Notes: Please e-mail lab results to labs@stohlenvironmental.com Rfrancoine@stohlenvironmental.com

Sampled By: Isaia Sciabarassi Print Name Isaia Sciabarassi Stohl Env: Isaia Sciabarassi Date: 6/26/2025

Relinquished By: Rebecca Franjoine Print Name Rebecca Franjoine Stohl Env: Rebecca Franjoine Date: 7/2/2025

Received (Name / Lab): ALS Date: 7/2/25 Time: 1620

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____





Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-199.4

Client: E2CC BOCES

Contact: Scott Rutkowski

Building: LoGuidice

Location: 9520 Fredonia-Stockton Road Fredonia, NY 14063

LEAD

Water by 200.8 X

Turnaround

10 Days

Sample #	Location	Outlet Type	Time
199.4D-03	br sink left of ktichen	s	23:48
199.4D-04	kitchen sink	s	23:50
199.4T-01	402 boys br	s	23:52
199.4T-02 A	dfb 400	df	23:54
199.4T-02 B	dfb 400	dfb	23:56
199.4T-03	404 girls br	s	23:58
199.4T-04	400 sink	s	0:00
199.4T-05	401 grooming area	sprayer	0:02
199.4T-06	403 rabbit room	sink	0:04
199.4T-07	403 A rodent room	sink	0:06
199.4T-08	304 student lav	s	0:08
199.4T-09	300 df	df	0:10
199.4T-10	300 utility sink	s	0:12
199.4T-11	302 staff lav	s	0:14
199.4T-12	203 womens lav	s	0:16
199.4T-13	200 df	df	0:18
199.4T-14	201 mens lav	s	0:20
199.4T-15	200 utility sink	s	0:22

Notes: Please e-mail lab results to labs@stohlenvironmental.com Rfranjoine@stohlenvironmental.com

Sampled By: Isaia Sciabarassi Print Name Stohl Env: Isaia Sciabarassi Date: 6/26/2025
 Relinquished By: Rebecca Franjoine Print Name Stohl Env: Rebecca Franjoine Date: 7/2/2025
 Received (Name / Lab): [Signature] ALS Date: 7/2/25 Time: 1620
 Sample Login (Name / Lab): _____ Date: _____ Time: _____
 Analysis (Name / Lab): _____ Date: _____ Time: _____
 QA/QC Review (Name / Lab): _____ Date: _____ Time: _____
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



R2508360

5

Cooler Receipt and Preservation Check Form



Project/Client Stohl

Folder Number _____

Cooler received on 7/2/25 by MLW

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <u>N</u>
2	Custody papers properly completed (ink, signed)?	Y <u>N</u>
3	Did all bottles arrive in good condition (unbroken)?	Y <u>N</u>
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <u>N</u>

5a	Did VOA vials have sig* bubbles?	Y N <u>NA</u>
5b	Sig* bubbles: Alk? Y N <u>NA</u> Sulfide? Y N <u>NA</u>	
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as: Bulk Encore 5035set	<u>NA</u>

8. Temperature Readings Date: 7/7/25 Time: 1049 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>20.1</u>							
Within 0-6°C?	Y <u>N</u>	Y N	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: _____ Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: 5035 by MLW on 7/7 at 1049
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 7/14 Time: 0800 by: MLW

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO
- 13. Were dissolved metals filtered in the field? YES NO
- 14. Air Samples: Cassettes / Tubes Intact Y / N with MS Y / N Canisters Pressurized Tedlar® Bags Inflated NA

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>224524</u>	HNO ₃		<u>✓</u>	<u>No lot info</u>		<u>All</u>	<u>2 mL</u>	<u>2/20/15</u>	<u>≤2</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: _____
Explain all Discrepancies/ Other Comments: _____

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541

Labels secondary reviewed by: MLW *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the “Notes” column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an “immediate” hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory’s NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4

Service Request: R2508360

Sample Name: 199.4B-05
Lab Code: R2508360-001
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4B-06
Lab Code: R2508360-002
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4B-07
Lab Code: R2508360-003
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4B-08
Lab Code: R2508360-004
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4B-09A
Lab Code: R2508360-005
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4

Service Request: R2508360

Sample Name: 199.4B-09B
Lab Code: R2508360-006
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4B-10
Lab Code: R2508360-007
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4B-11
Lab Code: R2508360-008
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4B-12
Lab Code: R2508360-009
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4B-13A
Lab Code: R2508360-010
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4

Service Request: R2508360

Sample Name: 199.4B-13B
Lab Code: R2508360-011
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4B-14
Lab Code: R2508360-012
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4B-15
Lab Code: R2508360-013
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4C-01
Lab Code: R2508360-014
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4C-02
Lab Code: R2508360-015
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4

Service Request: R2508360

Sample Name: 199.4C-03
Lab Code: R2508360-016
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4D-01
Lab Code: R2508360-017
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4D-02
Lab Code: R2508360-018
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4D-03
Lab Code: R2508360-019
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4D-04
Lab Code: R2508360-020
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4

Service Request: R2508360

Sample Name: 199.4T-01
Lab Code: R2508360-021
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4T-02A
Lab Code: R2508360-022
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4T-02B
Lab Code: R2508360-023
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4T-03
Lab Code: R2508360-024
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4T-04
Lab Code: R2508360-025
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4

Service Request: R2508360

Sample Name: 199.4T-05
Lab Code: R2508360-026
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4T-06
Lab Code: R2508360-027
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4T-07
Lab Code: R2508360-028
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4T-08
Lab Code: R2508360-029
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4T-09
Lab Code: R2508360-030
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4

Service Request: R2508360

Sample Name: 199.4T-10
Lab Code: R2508360-031
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4T-11
Lab Code: R2508360-032
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4T-12
Lab Code: R2508360-033
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4T-13
Lab Code: R2508360-034
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4T-14
Lab Code: R2508360-035
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4

Service Request: R2508360

Sample Name: 199.4T-15
Lab Code: R2508360-036
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4T-16
Lab Code: R2508360-037
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN

Sample Name: 199.4T-17
Lab Code: R2508360-038
Sample Matrix: Drinking Water

Date Collected: 06/26/25
Date Received: 07/2/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
NMANSEN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7	200.2
200.8	200.2
6010C or 6010D	3005A/3010A
6020A or 6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010C or 6010D	3050B
6020A or 6020B	3050B
6010C or 6010D TCLP (1311) extract	3005A/3010A
6010C or 6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4B-05
Lab Code: R2508360-001

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	7.1	ug/L	1.0	1	07/21/25 10:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4B-06
Lab Code: R2508360-002

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.5	ug/L	1.0	1	07/21/25 11:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4B-07
Lab Code: R2508360-003

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.0	ug/L	1.0	1	07/21/25 11:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4B-08
Lab Code: R2508360-004

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	11.0	ug/L	1.0	1	07/21/25 11:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4B-09A
Lab Code: R2508360-005

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/21/25 11:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4B-09B
Lab Code: R2508360-006

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/21/25 11:08	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4B-10
Lab Code: R2508360-007

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	18.2	ug/L	1.0	1	07/21/25 11:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4B-11
Lab Code: R2508360-008

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.5	ug/L	1.0	1	07/21/25 11:19	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4B-12
Lab Code: R2508360-009

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/21/25 11:20	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4B-13A
Lab Code: R2508360-010

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/21/25 11:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4B-13B
Lab Code: R2508360-011

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/21/25 11:23	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4B-14
Lab Code: R2508360-012

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	07/21/25 11:24	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4B-15
Lab Code: R2508360-013

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	17.5	ug/L	1.0	1	07/21/25 11:26	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4C-01
Lab Code: R2508360-014

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/21/25 11:27	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4C-02
Lab Code: R2508360-015

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	50.2	ug/L	1.0	1	07/21/25 11:29	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4C-03
Lab Code: R2508360-016

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.3	ug/L	1.0	1	07/21/25 11:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4D-01
Lab Code: R2508360-017

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/21/25 11:34	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4D-02
Lab Code: R2508360-018

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.8	ug/L	1.0	1	07/21/25 11:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4D-03
Lab Code: R2508360-019

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	07/21/25 11:37	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4D-04
Lab Code: R2508360-020

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	07/21/25 11:38	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4T-01
Lab Code: R2508360-021

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	9.8	ug/L	1.0	1	07/21/25 11:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4T-02A
Lab Code: R2508360-022

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/21/25 11:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4T-02B
Lab Code: R2508360-023

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/21/25 11:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4T-03
Lab Code: R2508360-024

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	27.8	ug/L	1.0	1	07/21/25 11:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4T-04
Lab Code: R2508360-025

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.6	ug/L	1.0	1	07/21/25 11:56	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4T-05
Lab Code: R2508360-026

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.6	ug/L	1.0	1	07/21/25 11:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4T-06
Lab Code: R2508360-027

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.3	ug/L	1.0	1	07/21/25 12:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4T-07
Lab Code: R2508360-028

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	4.2	ug/L	1.0	1	07/21/25 12:03	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4T-08
Lab Code: R2508360-029

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	17.6	ug/L	1.0	1	07/21/25 12:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4T-09
Lab Code: R2508360-030

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.6	ug/L	1.0	1	07/21/25 12:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4T-10
Lab Code: R2508360-031

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.6	ug/L	1.0	1	07/21/25 12:07	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4T-11
Lab Code: R2508360-032

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	22.2	ug/L	1.0	1	07/21/25 12:09	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4T-12
Lab Code: R2508360-033

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	99.4	ug/L	1.0	1	07/21/25 12:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4T-13
Lab Code: R2508360-034

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	45.1	ug/L	1.0	1	07/21/25 12:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4T-14
Lab Code: R2508360-035

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	46.3	ug/L	1.0	1	07/21/25 12:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4T-15
Lab Code: R2508360-036

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	20.1	ug/L	1.0	1	07/21/25 12:14	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4T-16
Lab Code: R2508360-037

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	34.0	ug/L	1.0	1	07/21/25 12:18	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4T-17
Lab Code: R2508360-038

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25 16:20
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.2	ug/L	1.0	1	07/21/25 12:20	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2508360-MB1

Service Request: R2508360
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/21/25 10:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2508360-MB2

Service Request: R2508360
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	07/21/25 11:45	

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25
Date Analyzed: 07/21/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 199.4B-05
Lab Code: R2508360-001
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2508360-001MS		Duplicate Matrix Spike R2508360-001DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	7.1	26.8	20.0	98	26.8	20.0	99	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25
Date Analyzed: 07/21/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 199.4D-04
Lab Code: R2508360-020
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2508360-020MS		Duplicate Matrix Spike R2508360-020DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	1.6	21.4	20.0	99	22.6	20.0	105	70-130	5	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water

Service Request: R2508360
Date Collected: 06/26/25
Date Received: 07/02/25
Date Analyzed: 07/21/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 199.4T-01
Lab Code: R2508360-021
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2508360-021MS		Duplicate Matrix Spike R2508360-021DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	9.8	29.8	20.0	100	28.6	20.0	94	70-130	4	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water

Service Request: R2508360
Date Analyzed: 07/21/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2508360-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.0	20.0	100	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice/2023L-199.4
Sample Matrix: Drinking Water

Service Request: R2508360
Date Analyzed: 07/21/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2508360-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	19.9	20.0	99	85-115



September 09, 2025

Service Request No:R2510505

Michael Scinta
Stohl Environmental
3860 California Road
Orchard Park, NY 14219

Laboratory Results for: E2CC BOCES LoGuidice - Building E

Dear Michael,

Enclosed are the results of the sample(s) submitted to our laboratory August 23, 2025
For your reference, these analyses have been assigned our service request number **R2510505**.

All testing was performed according to our laboratory's quality assurance program and met the requirements of the TNI standards except as noted in the case narrative report. Any testing not included in the lab's accreditation is identified on a Non-Certified Analytes report. All results are intended to be considered in their entirety. ALS Environmental is not responsible for use of less than the complete report. Results apply only to the individual samples submitted to the lab for analysis, as listed in the report. The measurement uncertainty of the results included in this report is within that expected when using the prescribed method(s), and represented by Laboratory Control Sample control limits. Any events, such as QC failures or Holding Time exceedances, which may add to the uncertainty are explained in the report narrative or are flagged with qualifiers. The flags are explained in the Report Qualifiers and Definitions page of this report.

Please contact me if you have any questions. My extension is 7475. You may also contact me via email at Meghan.Pedro@alsglobal.com.

Respectfully submitted,

ALS Group USA, Corp. dba ALS Environmental

Meghan Pedro
Project Manager

CC: Rebecca
Franjoine

ADDRESS

1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623

PHONE +1 585 288 5380 | **FAX** +1 585 288 8475

ALS Group USA, Corp.
dba ALS Environmental



Narrative Documents

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E
Sample Matrix: Drinking Water

Service Request: R2510505
Date Received: 08/23/2025

CASE NARRATIVE

All analyses were performed consistent with the quality assurance program of ALS Environmental. This report contains analytical results for samples for the Tier II level requested by the client.

Sample Receipt:

Forty drinking water samples were received for analysis at ALS Environmental on 08/23/2025. Any discrepancies upon initial sample inspection are annotated on the sample receipt and preservation form included within this report. The samples were stored at minimum in accordance with the analytical method requirements.

Metals:

No significant anomalies were noted with this analysis.

A handwritten signature in black ink that reads "Meghan Pedro".

Approved by _____

Date 09/09/2025



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 199.4Q-01		Lab ID: R2510505-001					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.3			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-02		Lab ID: R2510505-002					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.7			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-03		Lab ID: R2510505-003					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	25.3			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-04		Lab ID: R2510505-004					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.1			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-05		Lab ID: R2510505-005					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.2			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-06		Lab ID: R2510505-006					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	28.2			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-07		Lab ID: R2510505-007					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.6			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-08		Lab ID: R2510505-008					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.7			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-09		Lab ID: R2510505-009					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	8.8			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-10		Lab ID: R2510505-010					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.1			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-11		Lab ID: R2510505-011					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	13.9			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-12		Lab ID: R2510505-012					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	13.0			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 199.4Q-13		Lab ID: R2510505-013					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	20.1			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-14		Lab ID: R2510505-014					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	17.7			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-15		Lab ID: R2510505-015					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	16.2			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-17		Lab ID: R2510505-018					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	19.1			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-18		Lab ID: R2510505-019					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	29.3			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-19		Lab ID: R2510505-020					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.7			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-20		Lab ID: R2510505-021					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	3.8			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-21		Lab ID: R2510505-022					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	5.0			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-22		Lab ID: R2510505-023					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	14.0			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-23		Lab ID: R2510505-024					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.1			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-24		Lab ID: R2510505-025					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.0			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-25		Lab ID: R2510505-026					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	17.8			1.0	ug/L	200.8	



SAMPLE DETECTION SUMMARY

This form includes only detections above the reporting levels. For a full listing of sample results, continue to the Sample Results section of this Report.

CLIENT ID: 199.4Q-26		Lab ID: R2510505-027					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	6.9			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-27		Lab ID: R2510505-028					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	1.2			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-28		Lab ID: R2510505-029					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	2.9			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-29		Lab ID: R2510505-030					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	10.8			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-30		Lab ID: R2510505-031					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	34.5			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-32		Lab ID: R2510505-033					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	10.5			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-33		Lab ID: R2510505-034					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	19.5			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-34		Lab ID: R2510505-035					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	12.8			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-35		Lab ID: R2510505-036					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	17.5			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-36		Lab ID: R2510505-037					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	29.1			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-37		Lab ID: R2510505-038					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	49.3			1.0	ug/L	200.8	
CLIENT ID: 199.4Q-38		Lab ID: R2510505-039					
Analyte	Results	Flag	MDL	MRL	Units	Method	
Lead, Total	872			10	ug/L	200.8	



Sample Receipt Information

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4

Service Request:R2510505

SAMPLE CROSS-REFERENCE

<u>SAMPLE #</u>	<u>CLIENT SAMPLE ID</u>	<u>DATE</u>	<u>TIME</u>
R2510505-001	199.4Q-01	8/14/2025	
R2510505-002	199.4Q-02	8/14/2025	
R2510505-003	199.4Q-03	8/14/2025	
R2510505-004	199.4Q-04	8/14/2025	
R2510505-005	199.4Q-05	8/14/2025	
R2510505-006	199.4Q-06	8/14/2025	
R2510505-007	199.4Q-07	8/14/2025	
R2510505-008	199.4Q-08	8/14/2025	
R2510505-009	199.4Q-09	8/14/2025	
R2510505-010	199.4Q-10	8/14/2025	
R2510505-011	199.4Q-11	8/14/2025	
R2510505-012	199.4Q-12	8/14/2025	
R2510505-013	199.4Q-13	8/14/2025	
R2510505-014	199.4Q-14	8/14/2025	
R2510505-015	199.4Q-15	8/14/2025	
R2510505-016	199.4Q-16A	8/14/2025	
R2510505-017	199.4Q-16B	8/14/2025	
R2510505-018	199.4Q-17	8/14/2025	
R2510505-019	199.4Q-18	8/14/2025	
R2510505-020	199.4Q-19	8/14/2025	
R2510505-021	199.4Q-20	8/14/2025	
R2510505-022	199.4Q-21	8/14/2025	
R2510505-023	199.4Q-22	8/14/2025	
R2510505-024	199.4Q-23	8/14/2025	
R2510505-025	199.4Q-24	8/14/2025	
R2510505-026	199.4Q-25	8/14/2025	
R2510505-027	199.4Q-26	8/14/2025	
R2510505-028	199.4Q-27	8/14/2025	
R2510505-029	199.4Q-28	8/14/2025	
R2510505-030	199.4Q-29	8/14/2025	
R2510505-031	199.4Q-30	8/14/2025	
R2510505-032	199.4Q-31	8/14/2025	
R2510505-033	199.4Q-32	8/14/2025	
R2510505-034	199.4Q-33	8/14/2025	
R2510505-035	199.4Q-34	8/14/2025	
R2510505-036	199.4Q-35	8/14/2025	
R2510505-037	199.4Q-36	8/14/2025	
R2510505-038	199.4Q-37	8/14/2025	
R2510505-039	199.4Q-38	8/14/2025	
R2510505-040	199.4Q-39A	8/14/2025	



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-199.4

Client: E2CC BOCES

Contact: Scott Rutkowski

Building: LoGuidice - Building E

Location: 9520 Fredonia-Stockton Road Fredonia, NY 14063

LEAD
 Water by 200.8 X

Turnaround
10 Days

Sample #	Location
199.4Q-01	201A Lav sink
199.4Q-02	201 high sink
199.4Q-03	201 low sink
199.4Q-04	203A Lav sink
199.4Q-05	203 high sink
199.4Q-06	203 low sink
199.4Q-07	205A Lav sink
199.4Q-08	205 high sink
199.4Q-09	205 low sink
199.4Q-10	207 sink
199.4Q-11	301 sink
199.4Q-12	303 sink
199.4Q-13	305 sink
199.4Q-14	307 sink
199.4Q-15	309 sink
199.4Q-16A	300 DF
199.4-16B	300 BF
199.4Q-17	310B lav sink

Outlet Type	Time
Sink	23:15
Sink	23:17
Sink	23:20
Sink	23:22
Sink	23:22
Sink	23:22
Sink	23:25
Sink	23:25
Sink	23:25
Sink	23:27
Sink	23:30
Sink	23:32
Sink	23:34
Sink	23:35
Sink	23:37
Drinking Fountain	23:40
Bottle Fille	23:40
Sink	23:42

Notes:
 Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to: Rfranjaine@stohlenvironmental.com

Sampled By: Isaia Sciabarassi Print Name Isaia Sciabarassi Stohl Env: Isaia Sciabarassi Date: 8/14/2025

Relinquished By: _____ Print Name _____ Stohl Env: M. Scinta Date: 8/23/2025

Received (Name / Lab): [Signature] Date: 8/23/25 Time: 9:25

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

R2510505 **5**
 Stohl Environmental
 E2CC BOCES LoGuidice - Building E



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) ALS

STOHL Job # 2023L-199.4

Client: E2CC BOCES

Contact: Scott Rutkowski

Building: LoGuidice - Building E

Location: 9520 Fredonia-Stockton Road Fredonia, NY 14063

LEAD
 Water by 200.8 X

Turnaround
10 Days

Sample #	Location	Outlet Type	Time
199.4Q-18	607 sink	Sink	23:48
199.4Q-19	614 Lav sink	Sink	23:50
199.4Q-20	614 high sink	Sink	23:52
199.4Q-21	614 drinking fountain	Drinking Fountain	23:54
199.4Q-22	614 low sink	Sink	23:57
199.4Q-23	610 lav sink	Sink	23:59
199.4Q-24	610 high sink	Sink	0:02
199.4Q-25	610 drink fountain	Drinking Fountain	0:04
199.4Q-26	610 low sink	Sink	0:06
199.4Q-27	608 lav sink	Sink	0:08
199.4Q-28	608 high sink	Sink	0:08
199.4Q-29	608 low sink	Sink	0:08
199.4Q-30	601 A left sink	Sink	0:10
199.4Q-31	601 A bottle fill on right sink	Spout	0:12
199.4Q-32	601 A right sink	Sink	0:15
199.4Q-33	605 high sink	Sink	0:17
199.4Q-34	103 lav sink left	Sink	0:20
199.4Q-35	103 lav sink right	Sink	0:20

Notes: Please e-mail lab results to labs@stohlenv.com Rfranjoine@stohlenvironmental.com

Sampled By: Isaia Sciabarassi Print Name Isaia Sciabarassi Stohl Env: Isaia Sciabarassi Date: 8/14/2025

Relinquished By: _____ Print Name _____ Stohl Env: M. Scinta Date: 8/23/2025

Received (Name / Lab): [Signature] Date: 8/23/25 Time: 9:25

Sample Login (Name / Lab): _____ Date: _____ Time: _____

Analysis (Name / Lab): _____ Date: _____ Time: _____

QA/QC Review (Name / Lab): _____ Date: _____ Time: _____

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



R2510505 5

Stohl Environmental
E2CC BOCES LeGouldice - Building E

Cooler Receipt and Preservation



Project/Client Stohl Folder Number _____

Cooler received on 8/23/25 by: UM

COURIER: ALS UPS FEDEX VELOCITY CLIENT

1	Were Custody seals on outside of cooler?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
2	Custody papers properly completed (ink, signed)?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
3	Did all bottles arrive in good condition (unbroken)?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>
4	Circle: Wet Ice Dry Ice Gel packs present?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>

5a	Did VOA vials have sig* bubbles?	Y N <input checked="" type="checkbox"/> NA
5b	Sig* bubbles: Alk?	Y N <input checked="" type="checkbox"/> NA
	Sulfide?	Y N <input checked="" type="checkbox"/> NA
6	Where did the bottles originate?	<u>ALS/ROC</u> CLIENT
7	Soil VOA received as:	Bulk Encore 5035set <input checked="" type="checkbox"/> NA

8. Temperature Readings Date: 8/23/25 Time: 9:33 ID: IR#12 IR#11 From: Temp Blank Sample Bottle

Temp (°C)	<u>21.9</u>						
Within 0-6°C?	Y <input checked="" type="checkbox"/> N <input type="checkbox"/>	Y N	Y N	Y N	Y N	Y N	Y N
If <0°C, were samples frozen?	Y N	Y N	Y N	Y N	Y N	Y N	Y N

If out of Temperature, note packing/ice condition: NO ICE Ice melted Poorly Packed (described below) Same Day Rule
& Client Approval to Run Samples: _____ Standing Approval Client aware at drop-off Client notified by: _____

All samples held in storage location: SMO by UM on 8/23/25 at 9:35
5035 samples placed in storage location: _____ by _____ on _____ at _____ within 48 hours of sampling? Y N

Cooler Breakdown/Preservation Check**: Date: 8/27/25 Time: 4:18 by: RM

- 9. Were all bottle labels complete (i.e. analysis, preservation, etc.)? YES NO
- 10. Did all bottle labels and tags agree with custody papers? YES NO
- 11. Were correct containers used for the tests indicated? YES NO
- 12. Were 5035 vials acceptable (no extra labels, not leaking)? YES NO
- 13. Were dissolved metals filtered in the field? YES NO

14. Air Samples: Cassettes / Tubes Intact Y/N with MS Y/N Canisters Pressurized Tedlar® Bags Inflated N/A

pH	Lot of test paper	Reagent	Preserved?		Lot Received	Exp	Sample ID Adjusted	Vol. Added	Lot Added	Final pH
			Yes	No						
≥12		NaOH								
≤2	<u>202325</u>	HNO ₃	-	✓			<u>All</u>	<u>4ml</u>	<u>242587</u>	<u>≤2</u>
≤2		H ₂ SO ₄								
<4		NaHSO ₄								
5-9		For 608pest			No=Notify for 3day					
Residual Chlorine (-)		For CN, Phenol, 625, 608pest, 522			If +, contact PM to add Na ₂ S ₂ O ₃ (625, 608, CN), ascorbic (phenol).					
		Na ₂ S ₂ O ₃								
		ZnAcetate	-	-						
		HCl	**	**						

**VOAs and 1664 Not to be tested before analysis. Otherwise, all bottles of all samples with chemical preservatives are checked (not just representatives).

Bottle lot numbers: 051225-2ADD, 090522-2ERG

Explain all Discrepancies/ Other Comments:
IO) Only sample ID on bottles

Labels secondary reviewed by: RM *significant air bubbles: VOA > 5-6 mm : WC > 1 in. diameter

HPROD	BULK
HTR	FLDT
SUB	HGFB
ALS	LL3541



Miscellaneous Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



REPORT QUALIFIERS AND DEFINITIONS

- U Analyte was analyzed for but not detected. The sample quantitation limit has been corrected for dilution and for percent moisture, unless otherwise noted in the case narrative.
- J Estimated value due to either being a Tentatively Identified Compound (TIC) or that the concentration is between the MRL and the MDL. Concentrations are not verified within the linear range of the calibration. For DoD: concentration >40% difference between two GC columns (pesticides/Aroclors).
- B Analyte was also detected in the associated method blank at a concentration that may have contributed to the sample result.
- E Inorganics- Concentration is estimated due to the serial dilution was outside control limits.
- E Organics- Concentration has exceeded the calibration range for that specific analysis.
- D Concentration is a result of a dilution, typically a secondary analysis of the sample due to exceeding the calibration range or that a surrogate has been diluted out of the sample and cannot be assessed.
- * Indicates that a quality control parameter has exceeded laboratory limits. Under the “Notes” column of the Form I, this qualifier denotes analysis was performed out of Holding Time.
- H Analysis was performed out of hold time for tests that have an “immediate” hold time criteria.
- # Spike was diluted out.
- + Correlation coefficient for MSA is <0.995.
- N Inorganics- Matrix spike recovery was outside laboratory limits.
- N Organics- Presumptive evidence of a compound (reported as a TIC) based on the MS library search.
- S Concentration has been determined using Method of Standard Additions (MSA).
- W Post-Digestion Spike recovery is outside control limits and the sample absorbance is <50% of the spike absorbance.
- P Concentration >40% difference between the two GC columns.
- C Confirmed by GC/MS
- Q DoD reports: indicates a pesticide/Aroclor is not confirmed ($\geq 100\%$ Difference between two GC columns).
- X See Case Narrative for discussion.
- MRL Method Reporting Limit. Also known as:
- LOQ Limit of Quantitation (LOQ)
The lowest concentration at which the method analyte may be reliably quantified under the method conditions.
- MDL Method Detection Limit. A statistical value derived from a study designed to provide the lowest concentration that will be detected 99% of the time. Values between the MDL and MRL are estimated (see J qualifier).
- LOD Limit of Detection. A value at or above the MDL which has been verified to be detectable.
- ND Non-Detect. Analyte was not detected at the concentration listed. Same as U qualifier.

Rochester Lab ID # for State Accreditations¹



NELAP States
Florida ID # E87674
New Hampshire ID # 2941
New York ID # 10145
Pennsylvania ID# 68-786
Texas ID#T104704581
Virginia #460167

Non-NELAP States
Connecticut ID #PH0556
Delaware Approved
Maine ID #NY01587
North Carolina #36701
North Carolina #676
Rhode Island LAO00333

¹ Analyses were performed according to our laboratory’s NELAP-approved quality assurance program and any applicable state or agency requirements. The test results meet requirements of the current NELAP/TNI standards or state or agency requirements, where applicable, except as noted in the case narrative. Since not all analyte/method/matrix combinations are offered for state/NELAC accreditation, this report may contain results which are not accredited. For a specific list of accredited analytes, contact the laboratory. To verify NH accredited analytes, go to <https://www4.des.state.nh.us/CertifiedLabs/Certified-Method.aspx>.

ALS Laboratory Group

Acronyms

ASTM	American Society for Testing and Materials
A2LA	American Association for Laboratory Accreditation
CARB	California Air Resources Board
CAS Number	Chemical Abstract Service registry Number
CFC	Chlorofluorocarbon
CFU	Colony-Forming Unit
DEC	Department of Environmental Conservation
DEQ	Department of Environmental Quality
DHS	Department of Health Services
DOE	Department of Ecology
DOH	Department of Health
EPA	U. S. Environmental Protection Agency
ELAP	Environmental Laboratory Accreditation Program
GC	Gas Chromatography
GC/MS	Gas Chromatography/Mass Spectrometry
LUFT	Leaking Underground Fuel Tank
M	Modified
MCL	Maximum Contaminant Level is the highest permissible concentration of a substance allowed in drinking water as established by the USEPA.
MDL	Method Detection Limit
MPN	Most Probable Number
MRL	Method Reporting Limit
NA	Not Applicable
NC	Not Calculated
NCASI	National Council of the Paper Industry for Air and Stream Improvement
ND	Not Detected
NIOSH	National Institute for Occupational Safety and Health
PQL	Practical Quantitation Limit
RCRA	Resource Conservation and Recovery Act
SIM	Selected Ion Monitoring
TPH	Total Petroleum Hydrocarbons
tr	Trace level is the concentration of an analyte that is less than the PQL but greater than or equal to the MDL.

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4

Service Request: R2510505

Sample Name: 199.4Q-01
Lab Code: R2510505-001
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-02
Lab Code: R2510505-002
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-03
Lab Code: R2510505-003
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-04
Lab Code: R2510505-004
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-05
Lab Code: R2510505-005
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4

Service Request: R2510505

Sample Name: 199.4Q-06
Lab Code: R2510505-006
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By
ECASTROVINCI

Analyzed By
NMANSEN

Sample Name: 199.4Q-07
Lab Code: R2510505-007
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-08
Lab Code: R2510505-008
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-09
Lab Code: R2510505-009
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-10
Lab Code: R2510505-010
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4

Service Request: R2510505

Sample Name: 199.4Q-11
Lab Code: R2510505-011
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-12
Lab Code: R2510505-012
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-13
Lab Code: R2510505-013
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-14
Lab Code: R2510505-014
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-15
Lab Code: R2510505-015
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4

Service Request: R2510505

Sample Name: 199.4Q-16A
Lab Code: R2510505-016
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-16B
Lab Code: R2510505-017
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-17
Lab Code: R2510505-018
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-18
Lab Code: R2510505-019
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-19
Lab Code: R2510505-020
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4

Service Request: R2510505

Sample Name: 199.4Q-20
Lab Code: R2510505-021
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-21
Lab Code: R2510505-022
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-22
Lab Code: R2510505-023
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-23
Lab Code: R2510505-024
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-24
Lab Code: R2510505-025
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4

Service Request: R2510505

Sample Name: 199.4Q-25
Lab Code: R2510505-026
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By
ECASTROVINCI

Analyzed By
NMANSEN

Sample Name: 199.4Q-26
Lab Code: R2510505-027
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-27
Lab Code: R2510505-028
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-28
Lab Code: R2510505-029
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-29
Lab Code: R2510505-030
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4

Service Request: R2510505

Sample Name: 199.4Q-30
Lab Code: R2510505-031
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-31
Lab Code: R2510505-032
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-32
Lab Code: R2510505-033
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-33
Lab Code: R2510505-034
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-34
Lab Code: R2510505-035
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

ALS Group USA, Corp.
dba ALS Environmental

Analyst Summary report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4

Service Request: R2510505

Sample Name: 199.4Q-35
Lab Code: R2510505-036
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-36
Lab Code: R2510505-037
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-37
Lab Code: R2510505-038
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-38
Lab Code: R2510505-039
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN

Sample Name: 199.4Q-39A
Lab Code: R2510505-040
Sample Matrix: Drinking Water

Date Collected: 08/14/25
Date Received: 08/23/25

Analysis Method
200.8

Extracted/Digested By

Analyzed By
MKASTAN



PREPARATION METHODS

The preparation methods associated with this report are found in these tables unless discussed in the case narrative.

INORGANIC

Water/Liquid Matrix

Analytical Method	Preparation Method
200.7	200.2
200.8	200.2
6010C or 6010D	3005A/3010A
6020A or 6020B	ILM05.3
9034 Sulfide Acid Soluble	9030B
SM 4500-CN-N-2016 Amenable and Residual Cyanide	SM 4500-CN-G and SM 4500-CN-B,C-2016
SM 4500-CN-E WAD Cyanide	SM 4500-CN-I

Solid/Soil/Non-Aqueous Matrix

Analytical Method	Preparation Method
6010C or 6010D	3050B
6020A or 6020B	3050B
6010C or 6010D TCLP (1311) extract	3005A/3010A
6010C or 6010D SPLP (1312) extract	3005A/3010A
7199	3060A
300.0 Anions/ 350.1/ 353.2/ SM 2320B/ SM 5210B/ 9056A Anions	DI extraction
For analytical methods not listed, the preparation method is the same as the analytical method reference.	

ORGANIC

Preparation Methods for Organic methods are listed in the header of the Results pages.

Regarding "Bulk/5035A":

For soil/solid samples submitted in soil jars for Volatiles analysis, the prep method is listed as "Bulk/5035A". The lab follows the closed-system EPA 5035A protocols once the sample is transferred to a sealed vial, but collection in bulk in soil jars does not follow the collection protocols listed in EPA 5035A. In accordance with the NYSDOH technical notice of October 2012, all results or reporting limits <200 ug/kg are to be considered estimated due to potential low bias.



Sample Results

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-01
Lab Code: R2510505-001

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.3	ug/L	1.0	1	08/29/25 17:46	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-02
Lab Code: R2510505-002

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.7	ug/L	1.0	1	08/29/25 17:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-03
Lab Code: R2510505-003

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	25.3	ug/L	1.0	1	08/29/25 17:52	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-04
Lab Code: R2510505-004

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.1	ug/L	1.0	1	08/29/25 17:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-05
Lab Code: R2510505-005

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.2	ug/L	1.0	1	08/29/25 17:55	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-06
Lab Code: R2510505-006

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	28.2	ug/L	1.0	1	08/28/25 16:05	08/28/25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-07
Lab Code: R2510505-007

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.6	ug/L	1.0	1	08/29/25 17:56	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-08
Lab Code: R2510505-008

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.7	ug/L	1.0	1	08/29/25 17:58	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-09
Lab Code: R2510505-009

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	8.8	ug/L	1.0	1	08/29/25 17:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-10
Lab Code: R2510505-010

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.1	ug/L	1.0	1	08/29/25 18:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-11
Lab Code: R2510505-011

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	13.9	ug/L	1.0	1	08/29/25 18:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-12
Lab Code: R2510505-012

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	13.0	ug/L	1.0	1	08/29/25 18:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-13
Lab Code: R2510505-013

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	20.1	ug/L	1.0	1	08/29/25 18:05	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-14
Lab Code: R2510505-014

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	17.7	ug/L	1.0	1	08/29/25 18:10	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-15
Lab Code: R2510505-015

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	16.2	ug/L	1.0	1	08/29/25 18:12	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-16A
Lab Code: R2510505-016

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	08/29/25 18:13	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-16B
Lab Code: R2510505-017

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	08/29/25 18:15	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-17
Lab Code: R2510505-018

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	19.1	ug/L	1.0	1	08/29/25 18:25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-18
Lab Code: R2510505-019

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	29.3	ug/L	1.0	1	08/29/25 18:30	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-19
Lab Code: R2510505-020

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.7	ug/L	1.0	1	08/29/25 18:32	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-20
Lab Code: R2510505-021

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	3.8	ug/L	1.0	1	08/29/25 18:33	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-21
Lab Code: R2510505-022

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	5.0	ug/L	1.0	1	08/29/25 18:35	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-22
Lab Code: R2510505-023

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	14.0	ug/L	1.0	1	08/29/25 18:36	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-23
Lab Code: R2510505-024

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.1	ug/L	1.0	1	08/29/25 18:41	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-24
Lab Code: R2510505-025

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.0	ug/L	1.0	1	08/29/25 18:42	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-25
Lab Code: R2510505-026

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	17.8	ug/L	1.0	1	08/28/25 16:06	08/28/25	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-26
Lab Code: R2510505-027

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	6.9	ug/L	1.0	1	08/29/25 18:44	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-27
Lab Code: R2510505-028

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	1.2	ug/L	1.0	1	08/29/25 18:45	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-28
Lab Code: R2510505-029

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	2.9	ug/L	1.0	1	08/29/25 18:47	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-29
Lab Code: R2510505-030

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	10.8	ug/L	1.0	1	08/29/25 18:48	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-30
Lab Code: R2510505-031

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	34.5	ug/L	1.0	1	08/29/25 18:50	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-31
Lab Code: R2510505-032

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	08/29/25 18:51	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-32
Lab Code: R2510505-033

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	10.5	ug/L	1.0	1	08/29/25 18:53	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-33
Lab Code: R2510505-034

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	19.5	ug/L	1.0	1	08/29/25 18:54	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-34
Lab Code: R2510505-035

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	12.8	ug/L	1.0	1	08/29/25 18:59	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-35
Lab Code: R2510505-036

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	17.5	ug/L	1.0	1	08/29/25 19:01	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-36
Lab Code: R2510505-037

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	29.1	ug/L	1.0	1	08/29/25 19:02	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-37
Lab Code: R2510505-038

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	49.3	ug/L	1.0	1	08/29/25 19:04	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-38
Lab Code: R2510505-039

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	872	ug/L	10	10	09/05/25 15:06	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: 199.4Q-39A
Lab Code: R2510505-040

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25 09:25

Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	08/29/25 19:16	



QC Summary Forms

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com



Metals

ALS Environmental—Rochester Laboratory
1565 Jefferson Road, Building 300, Suite 360, Rochester, NY 14623
Phone (585) 288-5380 Fax (585) 288-8475
www.alsglobal.com

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2510505-MB1

Service Request: R2510505
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Date Extracted	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	08/28/25 15:59	08/28/25	
Lead, Total	200.8	ND U	ug/L	1.0	1	08/29/25 17:33	NA	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2510505-MB2

Service Request: R2510505
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	08/29/25 18:22	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2510505-MB3

Service Request: R2510505
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	08/29/25 19:11	

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water
Sample Name: Method Blank
Lab Code: R2510505-MB4

Service Request: R2510505
Date Collected: NA
Date Received: NA
Basis: NA

Inorganic Parameters

Analyte Name	Analysis Method	Result	Units	MRL	Dil.	Date Analyzed	Q
Lead, Total	200.8	ND U	ug/L	1.0	1	09/05/25 15:02	

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25
Date Analyzed: 08/29/25

Duplicate Matrix Spike Summary
Inorganic Parameters

Sample Name: 199.4Q-16B
Lab Code: R2510505-017
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2510505-017MS		Duplicate Matrix Spike R2510505-017DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	21.4	20.0	107	21.4	20.0	107	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25
Date Analyzed: 08/29/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 199.4Q-17
Lab Code: R2510505-018
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2510505-018MS		Duplicate Matrix Spike R2510505-018DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	19.1	42.0	20.0	115	42.0	20.0	114	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25
Date Analyzed: 08/29/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 199.4Q-37
Lab Code: R2510505-038
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2510505-038MS		Duplicate Matrix Spike R2510505-038DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	49.3	73.8	20.0	122	73.9	20.0	123	70-130	<1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water

Service Request: R2510505
Date Collected: 08/14/25
Date Received: 08/23/25
Date Analyzed: 08/29/25

**Duplicate Matrix Spike Summary
Inorganic Parameters**

Sample Name: 199.4Q-39A
Lab Code: R2510505-040
Analysis Method: 200.8

Units: ug/L
Basis: NA

Analyte Name	Sample Result	Result	Matrix Spike R2510505-040MS		Duplicate Matrix Spike R2510505-040DMS		% Rec Limits	RPD	RPD Limit	
			Spike Amount	% Rec	Result	Spike Amount				% Rec
Lead, Total	ND U	21.1	20.0	105	21.4	20.0	107	70-130	1	20

Results flagged with an asterisk (*) indicate values outside control criteria.

Results flagged with a pound (#) indicate the control criteria is not applicable.

Percent recoveries and relative percent differences (RPD) are determined by the software using values in the calculation which have not been rounded.

Matrix Spike and Matrix Spike Duplicate Data is presented for information purposes only. The matrix may or may not be relevant to samples reported in this report. The laboratory evaluates system performance based on the LCS and LCSD control limits.

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water

Service Request: R2510505
Date Analyzed: 08/28/25 - 08/29/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2510505-LCS1

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	20.9	20.0	104	85-115
Lead, Total	200.8	20.7	20.0	104	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water

Service Request: R2510505
Date Analyzed: 08/29/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2510505-LCS2

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.2	20.0	111	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water

Service Request: R2510505
Date Analyzed: 08/29/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2510505-LCS3

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	22.4	20.0	112	85-115

ALS Group USA, Corp.
dba ALS Environmental

QA/QC Report

Client: Stohl Environmental
Project: E2CC BOCES LoGuidice - Building E/2023L-199.4
Sample Matrix: Drinking Water

Service Request: R2510505
Date Analyzed: 09/05/25

Lab Control Sample Summary
Inorganic Parameters

Units:ug/L
Basis:NA

Lab Control Sample
R2510505-LCS4

Analyte Name	Analytical Method	Result	Spike Amount	% Rec	% Rec Limits
Lead, Total	200.8	21.4	20.0	107	85-115

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2026
Issued April 01, 2025

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE
Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. CHRISTINE KUTZER NY Lab Id No: 10145
ALS ENVIRONMENTAL - ROCHESTER
1565 JEFFERSON ROAD BUILDING 300, SUITE 360
ROCHESTER, NY 14623

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Bacteriology	
Coliform, Total / E. coli (Qualitative)	SM 20, 21-23 9223B (-04) (Colliert)
Dissolved Gases	
Acetylene	RSK-175
Ethane	RSK-175
Ethene (Ethylene)	RSK-175
Methane	RSK-175
Propane	RSK-175
Fuel Additives	
Methyl tert-butyl ether	EPA 524.2
Naphthalene	EPA 524.2
Metals I	
Arsenic, Total	EPA 200.8 Rev. 5.4
Barium, Total	EPA 200.8 Rev. 5.4
Cadmium, Total	EPA 200.8 Rev. 5.4
Chromium, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Copper, Total	EPA 200.8 Rev. 5.4
Iron, Total	EPA 200.7 Rev. 4.4
Lead, Total	EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Mercury, Total	EPA 245.1 Rev. 3.0
Selenium, Total	EPA 200.8 Rev. 5.4
Silver, Total	EPA 200.7 Rev. 4.4
	EPA 200.8 Rev. 5.4
Zinc, Total	EPA 200.7 Rev. 4.4

Serial No.: 70111

Property of the New York State Department of Health. Certificates are valid only at the address shown and must be conspicuously posted by the laboratory. Continued accreditation depends on the laboratory's successful ongoing participation in the Program. Consumers may verify a laboratory's accreditation status online at <https://apps.health.ny.gov/pubdoh/applinks/wc/elsappublicweb/>, by phone (518) 485-6570 or by email to elap@health.ny.gov.

